

Office : 1059, Sector 43-B, Chandigarh | E-mail: Contfound@gmail.com
Mob.: 94170-18335, 98885-18335 | Telefax : 0172-4677059
GSTIN : 04AGVPB0204E2Z2

No. ST/1728

Dated: 15-09-2025

TO WHOM IT MAY CONCERN

It is certified that I have visited the school building of "**Aanchal International School, Sector: 41-D, Chandigarh (U.T.)**" on 15/09/2025. The inspection was carried out along with the *Vice Principal Ms. Neeju Rana*.

The School building has been constructed as a Composite Structure (Load bearing walls with intermediate RCC Columns) upto Basement + two storeys. The building was constructed in year 2005 as per old codal provisions. The Plot area of the building is 7777.937 Sq. Yds. and the combined covered area of all floors is approx. 2154.32 Sqm as per the plans produced by the Vice Principal.

On the visual inspection there were no major structural/deflection cracks observed. Minor cracks had appeared on the Junction of RCC Slab and brickwork, which the management was intimated. Rebound hammer tests and Ultrasonic pulse velocity was also carried out to determine the strength of concrete.

As on date the building is fit for running an educational institute, provided it is properly maintained and retrofitted. The validity of this certificate is one year.

For M/s Continental Foundations



1

STRUCTURAL STABILITY CERTIFICATE

Approved Structural Consultants : ★ CPWD ★ Chandigarh Administration ★ Haryana Roads & Bridges Corp. Ltd.
★ Haryana Police Housing Corp. Ltd. ★ HSCC ★ Panjab University, Chandigarh ★ Panchayati Raj Dept. (Punjab)
Approved Valuers For : ★ Income Tax Deptt. (GOI) ★ PNB (Punjab) ★ UCO Bank
★ HDFC ★ Chd. House Fed. ★ Haryana Police Housing Co-op Ltd.